

MAHARASHTRA POLLUTION CONTROL BOARD

Phone : (02382) 252672

No. MPC / SROL / 865

27/8/10



Sub-Regional Office
"Dev Towers" Opp. Tahsil Office,
Plot No. RL-2045
Barshi Road, LATUR - 413512

Natural Sugar & Allied Ind. Ltd.,

Date: 29/9/10 Inward No 6232 Date 7/10/10

Time 11-00 Sign of Clerk

Refered

Date

M/s. Natural sugar & Allied Ind. Ltd., vill - Ranjani
HS - Kallam dist - Osmanabad.

Sub : Result of analysis of JVS samples collected on 27/01/2010

ir,

This office has collected JVS samples from your factory on 27/01/2010. The results of analysis of above samples are given below.

S.No.	Parameters	Consented limits	Results of analysis of JVS samples
(JVS collected from outlet of ETP)			
1.	PH.	Between 5.5 to 9.0	7.1
2.	B.O.D.	Not to exceed 100 mg / l	90.0
3.	C.O.D.	Not to exceed 250 mg / l	240.0
4.	S.S.	Not to exceed 100 mg / l	44.0
5.	T.D.S.	Not to exceed 2100 mg / l	2760.0
6.	O & G.	Not to exceed 10 mg / l	8.0
7.	Chloride	Not to exceed 600 mg / l	160.0
8.	Sulphate	Not to exceed 1000 mg / l	187.0
9.			
10.			

Note : All results are expressed in mg/l except PH.

As seen from the above results the underlined figures shows that the quality of the effluent is not meeting the limits in the consent order.

As per the condition of the consent order you were required to provide adequate effluent treatment system for the treatment of effluents arising from your factory so that the quality of the treated effluent should meet the given standards.

The above results indicate that you have failed to provide adequate effluent treatment plant and contravening the conditions of the consent order thus violating the provisions of the water & C.P.) Act, 1974 & thereby you have rendered yourself liable for legal action.

You are hereby directed to improve that treatment system so that the treated effluent should satisfy the prescribed standard. The steps taken in this regard may be communicated to this office gently.

Failure shall be seriously viewed, which may please be noted.

(Signature)

Copy submitted to :-
The Regional Officer, M.P.C. Board, Aurangabad.
The C.A.D. (Cess wing) M.P.C.B. Thane.

Yours faithfully,

(Signature)
(V.P. Shelke)

I/c Sub - Regional Officer, Latur

MAHARASHTRA POLLUTION CONTROL BOARD

Phone 1 : 02402473461
 Phone 2 : 02402473461
 Fax : 02473462
 Website : <http://mpcb.gov.in>



Regional Laboratory
 A4/1 Paryavaran Bhavan
 Behind Dainik Lokpatra, MIDC
 Chikhalthane
 E-mail : soaurangabad@mpcb.gov.in

Report No: MPCB/RLAU/JVS/10/0260

Date : 19/07/2011

ANALYSIS REPORT-WATER (JVS)

Industry Name & Address	M/s Natural Sugar & Allied ind. Ltd. Vill. Ranjani Tal. Kallam dist. Osmanabad.	Industry Code	
Consent No		Type Of Industry	Sugar
Dt. & Time of Sample Collection	09/03/2011 03:30:00		
Sample ID	SROLT/JVS/10/00209	Sample Source	ETP
Lab Sample Code	RLAU/JVS/10/01753		
Sample Location	Outlet	Location Details	
Collected By	Venket Pandurangrao Shelke	Seal No.	
Dt. of Submission	15/03/2011	Dt. of Receipt	16/03/2011

Sr.No	Parameter	UoM	Results
1	pH		8.2
2	BOD	mg/lit	16.0
3	C.O.D	mg/lit	36.0
4	Suspended Solids	mg/lit	8.0
5	T.D.Solids	mg/lit	580.0
6	Chlorides	mg/lit	209.9
7	Sulphate	mg/lit	57.9600
8	Oil & Grease	mg/lit	BDL

NA : Not Analysed BDL : Below Detection Limit ND : Not Detectable UoM : Unit Of Measurement

Reviewed By

Shri.R.B.Sorte
 Scientific Officer

IC ,Regional Laboratory - Aurangabad

M
13/2/2011
1745

P

** Electronic report does not require signature

14/2

Natural Sugar & Allied Ind. Ltd..
 Inward No. 11311 Date 15/2/2011
 Time 5.50 Sign. of Clerk J...
 Referred to Sign
 Date Time

Natural Sugar & Allied Industries Ltd.

Inward No. 5538 Date 28/8/2012

Time 2:30 Sign. of Clerk

MAHARASHTRA POLLUTION CONTROL BOARD

Phone : 02382-252672

Fax :

No. MPC / SROL / 752



Sub-Regional Office

Maharashtra Pollution Control Board

Dev Towers, Opp. Tahasil Office,

Plot No. RL-2045

Barshi Road, LATUR - 413 512

To,

Date: 22/08/2012

M/s Natural sugar & Allied Ind. (sugar)

W-11 - Ranjini, to - kavam dist - osmanabad.

Sub. : Result of Analysis of JVS Samples Collectd On 10/1/2012

Sir,

This office has collectd JVS samples from your factory on 10/1/2012

The results of analysis of above samples are given below.

S.No	Parameters	Consented Limits	Results of analysis of JVS samples
			(JVS collectd from outlet of ETP)
1.	PH.	Between 5.5 to 9.0	8.0
2.	B.O.D.	Not to exceed 100 mg / l	56.5
3.	C.O.D.	Not to exceed 250 mg / l	148.0
4.	S.S.	Not to exceed 100 mg / l	24.0
5.	T.D.S.	Not to exceed 2100 mg / l	822.0
6.	O & G.	Not to exceed 10 mg / l	BDL
7.	Chloride	Not to exceed 600 mg / l	282.4
8.	Sulphate	Not to exceed 1000 mg / l	64.08
9.			
10.			

Note : All results are expressed in mg / L except PH.

As seen from the above result the underlined figures shows that the quality of the effluent is not meeting the limits in the consent order.

As per the condition of the consent order you were required to provide adequate effluent treatment system for the treatment of effluents arising from your factory so that the quality of the treated effluent should meet the given standards.

The above results indicate that you have failed to provide adequate effluent treatment plant and contravening the conditions of the consent order thus violating the provisions of the water (P & C.P.) Act, 1974 & thereby you have rendered yourself liable for legal action.

You are hereby directed to improve that treatment system so that the treated effluent should qualify the prescribed standard. The steps taken in this regard may be communicated to this office urgently.

Failure shall be seriously viewed, which may please be noted.

Copy submitted to :

1. The Regional officer, M.P.C. Board, Aurangabad.
- 2) The C.A.D. (Cess wing) M.P.C.B. Thane

Yours Faithfully,
Nitesh Shinde
27/8/12
Sub - Regional Officer, Latur

(M) (T) / O M
f. 218
File 28

MAHARASHTRA POLLUTION CONTROL BOARD

Phone1 : 02402473461
 Phone1 : 02402473461
 Fax : 02473462

Website : <http://mpcb.gov.in>



Regional Laboratory

A4/1 Paryavaran Bhavan
 Behind Dainik Lokpatra, MIDC
 Chikhalthana

E-mail : soaurangabad@mpcb.gov.in

Report No: MPCB/RLAU/JVS/13/0752

Date: 16/03/2014

ANALYSIS REPORT-WATER (JVS)

Industry Name & Address	M/s. Natural Sugar & Allied Industries, A/p. Ranjni, Tal- Kallam, Dist- Osmnabad	Industry Code	
Consent No		Type Of Industry	Sugar
Dt. & Time of Sample Collection	29/11/2013 04:37:00		

Sample ID	SROLT/JVS/13/00638	Sample Source	ETP
Lab Sample Code	RLAU/JVS/13/00947		
Sample Location	Outlet	Location Details	
Collected By	Dr. Bhagwaan Maknikar	Seal No.	
Dt. of Submission	06/12/2013	Dt. of Receipt	13/12/2013

Sr.No	Parameter	UoM	Results
1	BOD	mg/lit	12.0
2	C.O.D	mg/lit	48.0
3	Oil & Grease	mg/lit	BDL
4	pH		7.2
5	Suspended Solids	mg/lit	24.0
6	Chlorides	mg/lit	89.0
7	Sulphate	mg/lit	202.8
8	T.D.Solids	mg/lit	824.0

NA : Not Analysed BDL : Below Detection Limit ND : Not Detectable UoM : Unit Of Measurement

Reviewed By

Shri.V.R.Thakur
 Scientific Officer

I/C, Regional Laboratory - Aurangabad

MAHARASHTRA POLLUTION CONTROL BOARD

Phone1 : 02402473461
 Phone1 : 02402473461
 Fax : 02473462

Website : <http://mpcb.gov.in>



Regional Laboratory

A4/1 Paryavaran Bhavan
 Behind Danik Lokpatra, MIDC
 Chikhalthana

E-mail : soaurangabad@mpcb.gov.in

Report No: MPCB/RLAU/JVS/13/0772

Date: 08/04/2014

ANALYSIS REPORT-WATER (JVS)

Industry Name & Address	M/s Natural Sugar & Allied Ind., Ltd. Vill. Ranjani Tal. Kallam Dist. Osmanabad.	Industry Code	
Consent No		Type Of Industry	Sugar
Dt. & Time of Sample Collection	22/01/2014 06:15:00		

Sample ID	SROLT/JVS/13/00924	Sample Source	ETP
Lab Sample Code	RLAU/JVS/13/01268	Location Details	
Sample Location	Outlet	Seal No.	
Collected By	Dr. Bhagwaan Maknikar	Dt. of Receipt	15/02/2014
Dt. of Submission	11/02/2014		

Sr.No	Parameter	UoM	Results
1	BOD	mg/lit	40.0
2	C.O.D	mg/lit	712.0
3	Oil & Grease	mg/lit	8.0
4	pH		7.4
5	Suspended Solids	mg/lit	102.0
6	Chlorides	mg/lit	194.9
7	Sulphate	mg/lit	716.2
8	T.D.Solids	mg/lit	2826.0

NA : Not Analysed BDL : Below Detection Limit ND : Not Detectable UoM : Unit Of Measurement

Reviewed By

Shri.V.R.Thakur
 Scientific Officer

I/C ,Regional Laboratory - Aurangabad

MAHARASHTRA POLLUTION CONTROL BOARD

Phone1 : 02402473461
 Phone1 : 02402473461
 Fax : 02473462

Website : <http://mpcb.gov.in>



Regional Laboratory

A4/1 Paryavaran Bhavan
 Behind Dainik Lokpatra, MIDC
 Chikhalthana

E-mail : soaurangabad@mpcb.gov.in

Report No: MPCB/RLAU/JVS/14/1000

Date: 31/03/2015

ANALYSIS REPORT-WATER (JVS)

Industry Name & Address	Natural Sugar & Allied Ind Ltd, Ranjani, Tal-Kallam, Dist-Osmanabad	Industry Code	
Consent No		Type Of Industry	Sugar
Dt. & Time of Sample Collection	24/02/2015 10:25:00		

Sample ID	SROLT/JVS/14/01198	Sample Source	ETP
Lab Sample Code	RLAU/JVS/14/01798		
Sample Location	Outlet	Location Details	
Collected By	Dr. Bhagwaan Maknikar	Seal No.	
Dt. of Submission	26/02/2015	Dt. of Receipt	09/03/2015

Sr.No	Parameter	UoM	Results
1	BOD	mg/lit	750.0
2	C.O.D	mg/lit	2080.0
3	Oil & Grease	mg/lit	18.0
4	pH		6.1
5	Suspended Solids	mg/lit	384.0
6	Chlorides	mg/lit	389.9
7	Sulphate	mg/lit	4132.0
8	T.D.Solids	mg/lit	5934.0

NA : Not Analysed BDL : Below Detection Limit ND : Not Detectable UoM : Unit Of Measurement

Reviewed By

Shri.V.R.Thakur
 Scientific Officer
 I/C ,Regional Laboratory - Aurangabad

** Electronic report does not require signature

PROCESS MANAGER
 Natural Sugar & Allied Ind. Ltd
 Ranjani, Tal. Kallam, Dist. Osmanabad